

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE**

Ref No. 6385Date : 12/1/22

It is certified that an inspection team headed by Suresh Pamboli (SI) from Nagar Parishad Bundi inspected the ST. PAUL'S SR. SEC. SCHOOL, BUNDI on 11/1/22 and found that the drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Government.

The above valid for a period of 2022-23

(Signature)

Signature with Seal (Signature)Name Navir SinghDesignation COMMISSIONER M.C. Bundi

To

ST. PAUL'S SR. SEC. SCHOOL  
Chittor Road  
Bundi ( 323001)

**OFFICE OF THE JUNIOR CHEMIST**  
**Public Health Engineering Department Laboratory**  
**BUNDI (Rajasthan)**

**REPORT OF THE CHEMICAL EXAMINATION OF WATER**

No. Lab/Tech. ( chem. ) 2021 - 2022 /1183

Dated 21-12-21

To

Principal, St. Paul's SR. Sec. School  
Chittor Road Bundi ( Raj. )

District : Bundi  
Tehsil : Bundi

Referene Your Letter No. SPSB/ BND/274 Dt.: 08.12.21

Name of Sample Taker : Sh. Vikas Sharma

Date of Receipt : 08.12.2021

Date of Examination : 15.12.2021

Source	Water Purifier			
Location of Source	in School campus			
Village/Town	Bundi			
Date of Collection	08.12.2021			
Lab. Sample No.	553			
Note: All Results except PH are in mg/lit.				
1. PH	6.47			
2. Turbidity (NTU)	0.84			
3. Temperature (° C )	-			
4. Colour	-			
5. Odour	-			
6. Total Alkalinity	20			
7. Total Hardness ( as CaCo <sub>3</sub> )	20			
8. Calcium Hardness ( as CaCo <sub>3</sub> )	-			
9. Magnesium Hardness ( as CaCo <sub>3</sub> )	-			
10. Chloride ( as Cl <sup>-</sup> )	28			
11. Sulphate ( as So <sub>4</sub> <sup>2-</sup> )	2			
12. Nitrite ( as No <sub>2</sub> <sup>-</sup> )	-			
13. Nitrates ( as No <sub>3</sub> <sup>-</sup> )	13			
14. Fluorides ( as F <sup>-</sup> )	0.0984			
15. Total Dissolved Solids	89			
16. Residual Chlorine	-			
17	-			
18	-			
19	-			
20	-			

Remarks:- Sample Not collected by Lab

(G.L. Sharma)

Junior Chemist

P.H.E.D. Laboratory, Bundi

# OFFICE OF THE JUNIOR CHEMIST

Public Health Engineering Department Laboratory

BUNDI ( RAJASTHAN )

Bacteriological Examination Report

No.Lab./J.C./ 2021 – 2022/1184

To,

Date:- 21-12-21

Tehsil:- Bundi

Principal, St. Paul's SR. Sec. School, Chittor Road Bundi

Reference:- Your letter No.SPSB/BND/ 274 Date- 08.12.21

District:-Bundi

Name of Sample Taker :- Shri Vikas Sharma

Code No:- -----

Sample not collected by lab.

Lab. Sample No.	Date of Collection	Date of Exam.	Residual Chlorine mg/lit.	Particular of Sample	Coliform organism MPN/100 ML
1302	08.12.21	08.12.21 to 10.12.21	-	Water Purifier in School Campus	Nil



( G.L. Sharma )

Junior Chemist

PHED Lab Bundi